



ADDENDUM NO. 2 - MARCH 26, 2010

West Lafayette Campus
PHYSICS BUILDING ROOM 114
RENOVATION - 2010
Purdue University
West Lafayette, Indiana

Project ID: 8370
Building Index NO: P-4

SCHOLER CORPORATION
111 Walter Scholer Drive
LAFAYETTE, INDIANA

COMM. NO. 0918

THE FOLLOWING CHANGES AND CORRECTIONS SHALL APPLY AND BE A PART OF THE CONTRACT DOCUMENTS INCLUDING THE BIDDING DOCUMENTS, SPECIFICATIONS, AND DRAWINGS.

SPECIFICATIONS

SECTION 15855 - DIFFUSERS, REGISTERS AND GRILLES

1. Page 15855-2: At 'Article 3.3, paragraph 'A', delete subparagraph as written in its entirety and substitute the following subparagraph:

"A. After installation, verify that grilles are clean and clear of obstructions, packing, etc., and connected to ductwork prior to startup."

DRAWINGS

ARCHITECTURAL DRAWINGS

SHEET A-111 - FIRST FLOOR PLAN

1. At the 'DOOR SCHEDULE', at door openings '1-1' and '1-2', under the 'DOOR MAT'L' at both openings, delete the letters 'WD' as written and substitute the letter "EX. WD" at both openings.

END OF ADDENDUM