

ADDENDUM NO. 3 - APRIL 1, 2010

West Lafayette Campus  
 PHYSICS BUILDING ROOM 114  
 RENOVATION - 2010  
 Purdue University  
 West Lafayette, Indiana

Project ID: 8370  
 Building Index NO: P-4

SCHOLER CORPORATION  
 111 Walter Scholer Drive  
 LAFAYETTE, INDIANA

COMM. NO. 0918

THE FOLLOWING CHANGES AND CORRECTIONS SHALL APPLY AND BE A PART OF THE CONTRACT DOCUMENTS INCLUDING THE BIDDING DOCUMENTS, SPECIFICATIONS, AND DRAWINGS.

BIDDING DOCUMENTSADVERTISEMENT FOR BIDS

1. Change the first paragraph as follows: "The Trustees of Purdue University will receive sealed bids for the projects until 3:00 P.M. Eastern Daylight Time (EDT) Tuesday, the 6<sup>th</sup> day of April 2010 in the Parking Facilities Office, Visitor Information Center, 504 Northwestern Avenue., West Lafayette, IN 47907."

ADDENDUM NO. 1, MARCH 23, 2010SECTION 01010 - SUMMARY OF WORK

1. Page 01010-5: At 'Article 1.05', delete item 'G-1-a.', as written and substitute the follows:
  - "a. April 6, 2010
    - 1) Owner receives bids for project."

SECTION 06410 - CUSTOM PHENOLIC PANEL CASEWORK FABRICATION

1. Page 06410-5: At 'Article 2.04', paragraph 'B', subparagraph '2', subparagraph 'a', delete the words 'Fire Retardant (FR) Black Core' and substitute 'Standard Black Core'.

SECTION 09772 - PHENOLIC INTERIOR WALL PANEL AND FABRICATION

1. Page 09772-3: At 'Article 2.01', paragraph 'B', subparagraph '2', subparagraph 'a', delete the words 'Fire Retardant (FR) Black Core' and substitute 'Standard Black Core'.
2. Page 09772-3: At 'Article 2.01', paragraph 'B', subparagraph '4', delete subparagraph 'a' as written in it entirety and substitute the following:
  - "a. 5/8" thickness".
3. Page 09772-3: At 'Article 2.01', paragraph 'E', delete subparagraph '2' as written in it entirety and substitute the following:
  - "2. Weight (5/8 inch thick panel): 4.6 lbs per square foot.
4. Page 09772-4: At 'Article 2.02', paragraph 'C', subparagraph '2', subparagraph 'a', delete the words 'Fire Retardant (FR) Black Core' and insert 'Standard Black Core'.
5. Page 09772-4: At 'Article 2.02', paragraph 'C', subparagraph '3', delete subparagraph 'a' as written in it entirety and substitute the following:
  - "a. 5/8" thickness".

DRAWINGSARCHITECTURAL DRAWINGSSHEET A-111 - FIRST FLOOR PLAN

1. At '7/Detail' make the following changes:
  - "a. Change reference to 3/4" phenolic material to read:
    - "5/8" phenolic material"

"b. Change reference to 3/8" phenolic material to read:

"5/8" phenolic material"

SHEET A-401 - DETAILS

1. At all Details make the following changes:

- a. Change reference to 1/2" solid phenolic to 5/8" solid phenolic.

SHEET A-403 - DETAILS

1. At 1/Detail make the following changes:

- a. Change 3/8" solid phenolic material to 5/8" solid phenolic material.
- b. Delete 5/8" continuous phenolic blocking without substitution.
- c. Delete the note that reads "plywood blocking make continuous at each clip" in its entirety and substitute the following "continuous shim as required for alignment of z-clips and wall panels.
- d. Add note that reads: "Provide shims at the acoustical wall panels as required to make flush with solid phenolic wall panel system.

END OF ADDENDUM