

ADDENDUM NO. 1 - AUGUST 24, 2011


West Lafayette Campus
BIOCHEMISTRY BUILDING ROOMS 319 & 320 RENOVATION - 2011
Purdue University
West Lafayette, Indiana

Project ID: 11410
Building Index NO: B-1

SCHOLER CORPORATION
111 Walter Scholer Drive
LAFAYETTE, INDIANA

COMM. NO. 2010.27

THE FOLLOWING CHANGES AND CORRECTIONS SHALL APPLY AND BE A PART OF THE CONTRACT DOCUMENTS INCLUDING THE BIDDING DOCUMENTS, SPECIFICATIONS, AND DRAWINGS.



PROJECT MANUAL

SPECIFICATIONS

DIVISION 12 - FURNISHINGS

SECTION 12 3553 - LABORATORY CASEWORK AND RELATED MATERIAL

1. Page 12 3553-5: At 'Article 2.01, paragraph 'F', subparagraph '1', delete subparagraph 'e' as written in its entirety and substitute the following:
"e. Cabinet (casework) end panels:
 - 1) Cabinet (casework) end panels shall be finished at all locations. This shall included end panels which are not exposed to view.
 - 2) Finish and material shall match the cabinet (casework) fronts."
2. Page 12 3553-6: At 'Article 2.01, paragraph 'F', subparagraph '2', delete subparagraph 'g' as written in its entirety and substitute the following:
"g. Cabinet (casework) back (backside)panels:
 - 1) Cabinet (casework) back (backside) panels shall be finished at all locations. This shall included back (backside) panels which are not exposed to view.
 - 2) Finish and material shall match the cabinet (casework) fronts."
3. Page 12 3553-7: At 'Article 2.01, paragraph 'G', subparagraph '10', delete subparagraph 'a' as written in its entirety and substitute the following:
 - "a. Provide 3/8 inch leveling screws at each bottom corner of each casework unit.
 - b. Submit product data and mounting details for review by Architect."

DRAWINGS

ARCHITECTURAL

SHEET A-102 - ELEVATIONS AND DETAILS

1. At Elevation '6/ELEVATION', make the following changes:
 - a. Delete the words which read 'DECK-MOUNTED MIXING FAUCET - WATERSAVER #32W405SG' and substitute the following:
"DECK-MOUNTED MIXING FAUCET - WATERSAVER #33L46500, TYP."
 - b. Delete the word which read 'DECK-MOUNTED DE-IONIZED WATER FAUCET - WATERSAVER #33L22900' and substitute the following:
"DECK-MOUNTED DE-IONIZED WATER FAUCET - WATERSAVER #32W51400, TYP."
2. At Elevation '2/ELEVATION', make the following change:
 - a. Add the following note with a leader arrow point to the faucet labeled 'CW'
"DECK-MOUNTED, SINGLE VALVE FAUCET - WATERSAVER #32W393CO'

3. At Elevation '3/ELEVATION', make the following change:
 - a. Add the following note with a leader arrow point to the faucet labeled 'CW'
"DECK-MOUNTED, SINGLE VALVE FAUCET - WATERSAVER #32W393CO'
4. At Elevation '4/ELEVATION', make the following change:
 - a. Add the following note with a leader arrow point to the faucet labeled 'CW'
"DECK-MOUNTED, SINGLE VALVE FAUCET - WATERSAVER #32W393CO'

END OF ADDENDUM